

**OFFICIAL REPORT
ON FIRE RATING CLASSIFICATION**

drawn up in conformity with the article 5 of the order dated November 21, 2002 modified

VALIDITY 5 YEARS (until March the 23th, 2023)

N° 19726-18/A

MATERIAL PRESENTED BY : GARNICA PLYWOOD VALENCIA DE DON JUAN
Ctra Villafer, km 2
24200 Valencia de Don Juan (León)
ESPAGNE

COMMERCIAL BRAND NAME : FIRESHIELD POPLARPLY

BRIEF DESCRIPTION : Wooden plywood panel made of poplar, with fire retardant.
The panel 5 mm thick is constituted of 3 plies, and the panel
50 mm thick is constituted of 23 plies.
Density : 530 kg/m³
Thicknesses : 5 and 50 mm
Colour presented : Light brown

TYPE OF TESTS : Test by radiation before and after ageing

CLASSEMENT : M1 available for the thicknesses between 5
and 50 mm.

* Classification only valid for any product not subjected to the CE mark

DURABILITY OF CLASSIFICATION : no limited.

Taking into account the criteria resulting from the test described in the appended test report n°19726-18/A of March the 23th, 2018
This certificate certifies that only the characteristics of the sample subjected to the tests and does not prejudice the characteristics of similar
products. So, this is not a certification of products in accordance with the article L. 115-27 of the consumer code and of the law of the June 3rd,
1994.

At Le Bouchet, March the 23th, 2018
Head of the "Fire testing" laboratory

Hélène BARBIER

